

SUMMARY REPORT  
20 ELDERBERRY DRIVE (FORMERLY 401 ELDERBERRY DRIVE)  
LAUREL BAY MILITARY HOUSING AREA  
MARINE CORPS AIR STATION BEAUFORT  
BEAUFORT, SC

Revision: 0  
Prepared for:

Department of the Navy  
Naval Facilities Engineering Command, Mid-Atlantic  
9324 Virginia Avenue  
Norfolk, Virginia 23511-3095

and



Naval Facilities Engineering Command Atlantic  
9324 Virginia Avenue  
Norfolk, Virginia 23511-3095

JUNE 2021

SUMMARY REPORT  
20 ELDERBERRY DRIVE (FORMERLY 401 ELDERBERRY DRIVE)  
LAUREL BAY MILITARY HOUSING AREA  
MARINE CORPS AIR STATION BEAUFORT  
BEAUFORT, SC

Revision: 0  
Prepared for:

Department of the Navy  
Naval Facilities Engineering Command, Mid- Atlantic  
9324 Virginia Avenue  
Norfolk, Virginia 23511-3095

and



Naval Facilities Engineering Command Atlantic

9324 Virginia Avenue  
Norfolk, Virginia 23511-3095

Prepared by:



CDM - AECOM Multimedia Joint Venture  
10560 Arrowhead Drive, Suite 500  
Fairfax, Virginia 22030

Contract Number: N62470-14-D-9016  
CTO WE52  
JUNE 2021

---

## Table of Contents

1.0	INTRODUCTION.....	1
1.1	BACKGROUND INFORMATION.....	1
1.2	UST REMOVAL AND ASSESSMENT PROCESS.....	2
2.0	SAMPLING ACTIVITIES AND RESULTS.....	3
2.1	UST REMOVAL AND SOIL SAMPLING .....	3
2.2	SOIL ANALYTICAL RESULTS.....	4
3.0	PROPERTY STATUS .....	4
4.0	REFERENCES.....	4

## Table

Table 1	Laboratory Analytical Results - Soil
---------	--------------------------------------

## Appendices

Appendix A	Multi-Media Selection Process for LBMH
Appendix B	UST Assessment Report
Appendix C	Regulatory Correspondence

---

## List of Acronyms

bgs	below ground surface
BTEX	benzene, toluene, ethylbenzene, and xylenes
CTO	Contract Task Order
COPC	constituents of potential concern
IDIQ	Indefinite Delivery, Indefinite Quantity
IGWA	Initial Groundwater Assessment
JV	Joint Venture
LBMH	Laurel Bay Military Housing
MCAS	Marine Corps Air Station
NAVFAC Mid-Lant	Naval Facilities Engineering Command Mid-Atlantic
NFA	No Further Action
PAH	polynuclear aromatic hydrocarbon
QAPP	Quality Assurance Program Plan
RBSL	risk-based screening level
SCDHEC	South Carolina Department of Health and Environmental Control
Site	LBMH area at MCAS Beaufort, South Carolina
UST	underground storage tank
VISL	vapor intrusion screening level

## 1.0 INTRODUCTION

The CDM - AECOM Multimedia Joint Venture (JV) was contracted by the Naval Facilities Engineering Command, Mid-Atlantic (NAVFAC Mid-Lant) to provide reporting services for the heating oil underground storage tanks (USTs) located in Laurel Bay Military Housing (LBMH) area at the Marine Corps Air Station (MCAS) Beaufort, South Carolina (Site). This work has been awarded under Contract Task Order (CTO) WE52 of the Indefinite Delivery, Indefinite Quantity (IDIQ) Multimedia Environmental Compliance Contract (Contract No. N62470-14-D-9016).

As of January 2014, the LBMH addresses were re-numbered to comply with the E-911 emergency response addressing system; however, in order to remain consistent with historical sampling and reporting for LBMH area, the residences will continue to be referenced with their original address numbers in sample nomenclature and reporting documents.

This report summarizes the results the environmental investigation activities associated with the storage of home heating oil and the potential release of petroleum constituents at the referenced property. Based on the results of the investigation, a No Further Action (NFA) determination has been made by the South Carolina Department of Health and Environmental Control (SCDHEC) for 20 Elderberry Drive (Formerly 401 Elderberry Drive). This NFA determination indicates that there are no unacceptable risks to human health or the environment for the petroleum constituents associated with the home heating oil USTs. The following information is included in this report:

- Background information;
- Sampling activities and results; and
- A determination of the property status.

### 1.1 Background Information

The LBMH area is located approximately 3.5 miles west of MCAS Beaufort. The area is approximately 970 acres in size and serves as an enlisted and officer family housing area. The area is configured with single family and duplex residential structures, and includes recreation, open space, and community facilities. The community includes approximately 1,300 housing units, including legacy Capehart style homes and newer duplex style homes. The housing area

is bordered on the west by salt marshes and the Broad River, and to the north, east and south by uplands. Forested areas lie along the northern and northeastern borders.

Capehart style homes within the LBMH area were formerly heated using heating oil stored in USTs at each residence. There were 1,100 Capehart style housing units in the LBMH area. The newer duplex homes within the LBMH area never utilized heating oil tanks. Heating oil has not been used at Laurel Bay since the mid-1980s. As was the accepted practice at the time, USTs were drained, filled with dirt, capped, and left in place when they were removed from service. Residential USTs are not regulated in the State of South Carolina (i.e., there are no federal or state laws governing installation, management, or removal).

In 2007, MCAS Beaufort began a voluntary program to remove the unregulated, residential USTs and conduct sampling activities to determine if, and to what extent, petroleum constituents may have impacted the surrounding environment. MCAS Beaufort coordinated with SCDHEC to develop removal procedures that were consistent with procedural requirements for regulated USTs. All tank removal activities and follow-on actions are conducted in coordination with SCDHEC. To date, all known USTs have been removed from all residential properties within the LBMH area.

## 1.2 UST Removal and Assessment Process

During the UST removal process, a soil sample was collected from beneath the UST excavations (approximately 4 to 6 feet [ft] below ground surface [bgs]) and analyzed for a predetermined list of constituents of potential concern (COPCs) associated with the petroleum compounds found in home heating oil. These COPCs, derived from the *Quality Assurance Program Plan (QAPP) for the Underground Storage Tank Management Division, Revision 3.1* (SCDHEC, 2016) and the *Underground Storage Tank Assessment Instructions for Permanent Closure and Change-In-Service*, (SCDHEC, 2018), are as follows:

- benzene, toluene, ethylbenzene, and xylenes (BTEX),
- naphthalene, and
- five select polynuclear aromatic hydrocarbon (PAHs): benzo(a)anthracene, benzo(b)fluoranthene, benzo(k)fluoranthene, chrysene and dibenz(a,h)anthracene.

Soil sample results were submitted by MCAS Beaufort to SCDHEC utilizing SCDHEC's UST Assessment Report form. In accordance with SCDHEC's *QAPP for the UST Management*

*Division* (SCDHEC, 2016), the soil screening levels consists of SCDHEC risk-based screening levels (RBSLs). It should be noted that the RBSLs for select PAHs were revised in Revision 2.0 of the QAPP (SCDHEC, 2013) and were revised again in Revision 3.0 (SCDHEC, 2015). The screening levels used for evaluation at each site were those levels that were in effect at the time of reporting and review by SCDHEC.

The results of the soil sampling at each former UST location were used to determine if a potential for groundwater contamination exists (i.e., soil results greater than RBSLs) and subsequently to select properties for follow-up initial groundwater assessment (IGWA) sampling. The results of the IGWA sampling (if necessary) are used to determine the presence or absence of the aforementioned COPCs in groundwater and identify whether former UST locations will require additional delineation of COPCs in groundwater. In order to delineate the extent of impact to groundwater, permanent wells are installed and a sampling program is established for those former UST locations where IGWA sampling has indicated the presence of COPCs in excess of the SCDHEC RBSLs for groundwater. Groundwater analytical results are also compared to the site specific groundwater vapor intrusion screening levels (VISLs) to evaluate the potential for vapor intrusion and the necessity for an investigation associated with this media. A multi-media investigation selection process tree, applicable to the LBMH UST investigations, is presented as Appendix A.

## 2.0 SAMPLING ACTIVITIES AND RESULTS

The following section presents the sampling activities and associated results for 20 Elderberry Drive (Formerly 401 Elderberry Drive). Details regarding the soil investigation at this site are provided in the *SCDHEC UST Assessment Report – 401 Elderberry Drive* (MCAS Beaufort, 2015). The UST Assessment Report is provided in Appendix B.

### 2.1 UST Removal and Soil Sampling

On September 25, 2014, a single 280 gallon heating oil UST was removed from the back yard adjacent to the rear patio area at 20 Elderberry Drive (Formerly 401 Elderberry Drive). The former UST location is indicated on Figures 1 and 2 of the UST Assessment Report (Appendix B). The UST was removed and properly disposed of (i.e., shipped offsite for recycling or transported to a landfill). There was no visual evidence (i.e., staining or sheen) of petroleum impact at the time of the UST removal. According to the UST Assessment Report (Appendix B), the depth to the base of the UST was 6'2" bgs and a single soil sample was collected from that

depth. The sample was collected from the fill port side of the former UST to represent a worst case scenario.

Following UST removal, a soil sample was collected from the base of the excavation and shipped to an offsite laboratory for analysis of the petroleum COPCs. Sampling was performed in accordance with applicable South Carolina regulation R.61-92, Part 280 (SCDHEC, 2017) and assessment guidelines.

## 2.2 Soil Analytical Results

A summary of the laboratory analytical results and SCDHEC RBSLs is presented in Table 1. A copy of the laboratory analytical data report is included in the UST Assessment Report presented in Appendix B. The laboratory analytical data report includes the soil results for the additional PAHs that were analyzed, but do not have associated RBSLs.

The soil sample results were submitted by MCAS Beaufort to SCDHEC utilizing SCDHEC's UST Assessment Report form (Appendix B). The results of the soil sampling at the former UST location were used by MCAS Beaufort, in consultation with SCDHEC, to determine a path forward (i.e., additional sampling or NFA) for the property. The soil results collected from 20 Elderberry Drive (Formerly 401 Elderberry Drive) were less than the SCDHEC RBSLs, which indicated the subsurface was not impacted by COPCs associated with the former UST at concentrations that presented a potential risk to human health and the environment.

## 3.0 PROPERTY STATUS

Based on the analytical results for soil, SCDHEC made the determination that NFA was required for 20 Elderberry Drive (Formerly 401 Elderberry Drive). This NFA determination was obtained in a letter dated July 1, 2015. SCDHEC's NFA letter is provided in Appendix C.

## 4.0 REFERENCES

Marine Corps Air Station Beaufort, 2015. *South Carolina Department of Health and Environmental Control (SCDHEC) Underground Storage Tank Assessment Report – 401 Elderberry Drive, Laurel Bay Military Housing Area*, March 2015.

South Carolina Department of Health and Environmental Control Bureau of Land and Waste Management, 2013. *Quality Assurance Program Plan for the Underground Storage Tank Management Division, Revision 2.0*, April 2013.



South Carolina Department of Health and Environmental Control Bureau of Land and Waste Management, 2015. *Quality Assurance Program Plan for the Underground Storage Tank Management Division, Revision 3.0*, May 2015.

South Carolina Department of Health and Environmental Control Bureau of Land and Waste Management, 2016. *Quality Assurance Program Plan for the Underground Storage Tank Management Division, Revision 3.1*, February 2016.

South Carolina Department of Health and Environmental Control Bureau of Land and Waste Management, 2017. *R.61-92, Part 280, Underground Storage Tank Control Regulations*, March 2017.

South Carolina Department of Health and Environmental Control Bureau of Land and Waste Management, 2018. *Underground Storage Tank Assessment Instructions for Permanent Closure and Change-In-Service*, March 2018.

## Table

**Table 1**  
**Laboratory Analytical Results - Soil**  
**20 Elderberry Drive (Formerly 401 Elderberry Drive)**  
**Laurel Bay Military Housing Area**  
**Marine Corps Air Station Beaufort**  
**Beaufort, South Carolina**

Constituent	SCDHEC RBSLs <sup>(1)</sup>	Results Sample Collected 09/25/14
<b>Volatile Organic Compounds Analyzed by EPA Method 8260B (mg/kg)</b>		
Benzene	0.003	ND
Ethylbenzene	1.15	ND
Naphthalene	0.036	ND
Toluene	0.627	ND
Xylenes, Total	13.01	ND
<b>Semivolatile Organic Compounds Analyzed by EPA Method 8270D (mg/kg)</b>		
Benzo(a)anthracene	0.66	ND
Benzo(b)fluoranthene	0.66	ND
Benzo(k)fluoranthene	0.66	ND
Chrysene	0.66	ND
Dibenz(a,h)anthracene	0.66	ND

**Notes:**

<sup>(1)</sup> South Carolina Risk-Based Screening Levels from the Quality Assurance Program Plan for the Underground Storage Tank Management Division, Revision 3.0 and 3.1 (SCDHEC, May 2015 and SCDHEC, February 2016) and the Underground Storage Tank Assessment Guidelines (SCDHEC, February 2006).

Bold font indicates the analyte was detected.

Bold font and shading indicates the concentration exceeds the SCDHEC RBSL.

EPA - United States Environmental Protection Agency

mg/kg - milligram per kilogram

ND - not detected at the reporting limit (or method detection limit if shown on the laboratory report). The laboratory report is provided in Appendix B.

RBSL - Risk-Based Screening Level

SCDHEC - South Carolina Department Of Health and Environmental Control

**Appendix A**  
**Multi-Media Selection Process for LBMH**



Appendix A - Multi-Media Selection Process for LBMH

**Appendix B**  
**UST Assessment Report**

South Carolina Department of Health and Environmental Control (SCDHEC)  
**Underground Storage Tank (UST) Assessment Report**



Submit Completed Form To:  
 UST Program  
 SCDHEC  
 2600 Bull Street  
 Columbia, South Carolina 29201  
 Telephone (803) 896-7957

SG DHEC - Bureau of  
 Land & Waste Management

**I. OWNERSHIP OF UST (S)**

MCAS Beaufort, Commanding Officer Attn: NREAO (Craig Ehde)		
Owner Name (Corporation, Individual, Public Agency, Other)		
P.O. Box 55001		
Mailing Address		
Beaufort,	South Carolina	29904-5001
City	State	Zip Code
843	228-7317	Craig Ehde
Area Code	Telephone Number	Contact Person

**II. SITE IDENTIFICATION AND LOCATION**

Permit I.D. #	
Laurel Bay Military Housing Area, Marine Corps Air Station, Beaufort, SC	
Facility Name or Company Site Identifier	
401 Elderberry Drive, Laurel Bay Military Housing Area	
Street Address or State Road (as applicable)	
Beaufort,	Beaufort
City	County

### III. INSURANCE INFORMATION

#### Insurance Statement

The petroleum release reported to DHEC on \_\_\_\_\_ at Permit ID Number \_\_\_\_\_ may qualify to receive state monies to pay for appropriate site rehabilitation activities. Before participation is allowed in the State Clean-up fund, written confirmation of the existence or non-existence of an environmental insurance policy is required. **This section must be completed.**

Is there now, or has there ever been an insurance policy or other financial mechanism that covers this UST release? YES \_\_\_\_ NO \_\_\_\_ (check one)

If you answered YES to the above question, please complete the following information:

My policy provider is: \_\_\_\_\_  
The policy deductible is: \_\_\_\_\_  
The policy limit is: \_\_\_\_\_

If you have this type of insurance, please include a copy of the policy with this report.

### IV. REQUEST FOR SUPERB FUNDING

I **DO** / **DO NOT** wish to participate in the SUPERB Program. (Circle one.)

### V. CERTIFICATION (To be signed by the UST owner)

**I certify that I have personally examined and am familiar with the information submitted in this and all attached documents; and that based on my inquiry of those individuals responsible for obtaining this information, I believe that the submitted information is true, accurate, and complete.**

\_\_\_\_\_  
Name (Type or print.)

\_\_\_\_\_  
Signature

#### To be completed by Notary Public:

Sworn before me this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_

\_\_\_\_\_  
(Name)

Notary Public for the state of \_\_\_\_\_.  
*Please affix State seal if you are commissioned outside South Carolina*



## VI. UST INFORMATION

- A. Product...(ex. Gas, Kerosene).....
- B. Capacity..(ex. 1k, 2k).....
- C. Age.....
- D. Construction Material..(ex. Steel, FRP).....
- E. Month/Year of Last Use.....
- F. Depth (ft.) To Base of Tank.....
- G. Spill Prevention Equipment Y/N.....
- H. Overfill Prevention Equipment Y/N.....
- I. Method of Closure Removed/Filled.....
- J. Date Tanks Removed/Filled.....
- K. Visible Corrosion or Pitting Y/N.....
- L. Visible Holes Y/N.....

401 Elderberry				
Heating oil				
280 gal				
Late 1950s				
Steel				
Mid 1980s				
6'2"				
No				
No				
Removed				
9/25/2014				
Yes				
Yes				

- M. Method of disposal for any USTs removed from the ground (attach disposal manifests)  
UST 401Elderberry was removed from the ground and disposed at a  
Subtitle "D" landfill. See Attachment "A".
- 
- N. Method of disposal for any liquid petroleum, sludges, or wastewaters removed from the USTs (attach disposal manifests)  
UST 401Elderberry had been previously filled with sand by others.
- 
- O. If any corrosion, pitting, or holes were observed, describe the location and extent for each UST  
Corrosion, pitting and holes were found throughout the tank.
-

## VII. PIPING INFORMATION

A. Construction Material..(ex. Steel, FRP).....

B. Distance from UST to Dispenser.....

C. Number of Dispensers.....

D. Type of System Pressure or Suction.....

E. Was Piping Removed from the Ground? Y/N

F. Visible Corrosion or Pitting Y/N.....

G. Visible Holes Y/N.....

H. Age.....

I. If any corrosion, pitting, or holes were observed, describe the location and extent for each piping run.

401 Elderberry				
Steel & Copper				
N/A				
N/A				
Suction				
No				
Yes				
No				
Late 1950s				

Corrosion and pitting were found on the surface of the steel vent pipe. Copper supply and return lines were sound.

## VIII. BRIEF SITE DESCRIPTION AND HISTORY

The USTs at the residences are constructed of single wall steel and formerly contained fuel oil for heating. These USTs were installed in the late 1950s and last used in the mid 1980s.

## IX. SITE CONDITIONS

	Yes	No	Unk
<p>A. Were any petroleum-stained or contaminated soils found in the UST excavation, soil borings, trenches, or monitoring wells?</p> <p>If yes, indicate depth and location on the site map.</p>		X	
<p>B. Were any petroleum odors detected in the excavation, soil borings, trenches, or monitoring wells?</p> <p>If yes, indicate location on site map and describe the odor (strong, mild, etc.)</p>		X	
<p>C. Was water present in the UST excavation, soil borings, or trenches?</p> <p>If yes, how far below land surface (indicate location and depth)?</p>		X	
<p>D. Did contaminated soils remain stockpiled on site after closure?</p> <p>If yes, indicate the stockpile location on the site map.</p> <p>Name of DHEC representative authorizing soil removal:</p>		X	
<p>E. Was a petroleum sheen or free product detected on any excavation or boring waters?</p> <p>If yes, indicate location and thickness.</p>		X	

## X. SAMPLE INFORMATION

A. SCDHEC Lab Certification Number 84009

B.

Sample #	Location	Sample Type (Soil/Water)	Soil Type (Sand/Clay)	Depth*	Date/Time of Collection	Collected by	OVA #
401 Elderby	Excav at fill end	Soil	Sandy	6'2"	9/25/14 1245 hrs	P. Shaw	
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

\* = Depth Below the Surrounding Land Surface

## XI. SAMPLING METHODOLOGY

Provide a detailed description of the methods used to collect and store the samples. Also include the preservative used for each sample. Please use the space provided below.

Sampling was performed in accordance with SC DHEC R.61-92 Part 280 and SC DHEC Assessment Guidelines. Sample containers were prepared by the testing laboratory. The grab method was utilized to fill the sample containers leaving as little head space as possible and immediately capped. Soil samples were extracted from area below tank. The samples were marked, logged, and immediately placed in a sample cooler packed with ice to maintain an approximate temperature of 4 degrees Centigrade. Tools were thoroughly cleaned and decontaminated with the seven step decon process after each use. The samples remained in custody of SBG-EEG, Inc. until they were transferred to Test America Incorporated for analysis as documented in the Chain of Custody Record.

---

---

---

---

---

---

---

---

---

---

## XII. RECEPTORS

	Yes	No
<p>A. Are there any lakes, ponds, streams, or wetlands located within 1000 feet of the UST system?</p> <p style="text-align: right;">*Stormwater drainage canal</p> <p>If yes, indicate type of receptor, distance, and direction on site map.</p>	*X	
<p>B. Are there any public, private, or irrigation water supply wells within 1000 feet of the UST system?</p> <p>If yes, indicate type of well, distance, and direction on site map.</p>		X
<p>C. Are there any underground structures (e.g., basements) Located within 100 feet of the UST system?</p> <p>If yes, indicate type of structure, distance, and direction on site map.</p>		X
<p>D. Are there any underground utilities (e.g., telephone, electricity, gas, water, sewer, storm drain) located within 100 feet of the UST system that could potentially come in contact with the contamination?</p> <p style="text-align: right;">*Sewer, water, electricity cable, fiber optic &amp; geothermal</p> <p>If yes, indicate the type of utility, distance, and direction on the site map.</p>	*X	
<p>E. Has contaminated soil been identified at a depth less than 3 feet below land surface in an area that is not capped by asphalt or concrete?</p> <p>If yes, indicate the area of contaminated soil on the site map.</p>		X


### **XIII. SITE MAP**

**You must supply a scaled site map. It should include all buildings, road names, utilities, tank and dispenser island locations, labeled sample locations, extent of excavation, and any other pertinent information.**

(Attach Site Map Here)



STORMWATER DRAINAGE  
CANAL  $\approx$  900'




UST 401ELDERBERRY

401 ELDERBERRY DRIVE  
LAUREL BAY MILITARY HOUSING  
MCAS BEAUFORT, SC

UST 401ELDERBERRY WAS  
38" BELOW GRADE.

GRAPHIC SCALE



***SBG-EEG***



7301 RIVERS AVE., SUITE 245  
N. CHARLESTON SC 29406  
(843) 573-7140

FIGURE 1 SITE MAP  
401 ELDERBERRY DRIVE, LAUREL BAY  
MCAS BEAUFORT SC


SCALE: GRAPHIC

DWG DATE OCT 2014





GRAPHIC SCALE



**SBG-EEG**

7301 RIVERS AVE., SUITE 245  
N. CHARLESTON SC 29406  
(843) 573-7140

FIGURE 2 UST SAMPLE LOCATIONS  
401 ELDERBERRY DRIVE, LAUREL BAY  
MCAS BEAUFORT SC

SCALE: GRAPHIC

DWG DATE OCT 2014



Picture 1: Location of UST 401Elderberry.



Picture 2: UST 401Elderberry excavation.



Picture 3: Site after completion of work.

#### XIV. SUMMARY OF ANALYSIS RESULTS

Enter the soil analytical data for each soil boring for all COC in the table below and on the following page.

<b>CoC</b>	<b>UST</b>	<b>401Elderberry</b>						
<b>Benzene</b>		ND						
<b>Toluene</b>		ND						
<b>Ethylbenzene</b>		ND						
<b>Xylenes</b>		ND						
<b>Naphthalene</b>		ND						
<b>Benzo (a) anthracene</b>		ND						
<b>Benzo (b) fluoranthene</b>		ND						
<b>Benzo (k) fluoranthene</b>		ND						
<b>Chrysene</b>		ND						
<b>Dibenz (a, h) anthracene</b>		ND						
<b>TPH (EPA 3550)</b>								

<b>CoC</b>								
<b>Benzene</b>								
<b>Toluene</b>								
<b>Ethylbenzene</b>								
<b>Xylenes</b>								
<b>Naphthalene</b>								
<b>Benzo (a) anthracene</b>								
<b>Benzo (b) fluoranthene</b>								
<b>Benzo (k) fluoranthene</b>								
<b>Chrysene</b>								
<b>Dibenz (a, h) anthracene</b>								
<b>TPH (EPA 3550)</b>								

### SUMMARY OF ANALYSIS RESULTS (cont'd)

Enter the ground water analytical data for each sample for all CoC in the table below. If free product is present, indicate the measured thickness to the nearest 0.01 feet.

CoC	RBSL (µg/l)	W-1	W-2	W -3	W -4
Free Product Thickness	None				
Benzene	5				
Toluene	1,000				
Ethylbenzene	700				
Xylenes	10,000				
Total BTEX	N/A				
MTBE	40				
Naphthalene	25				
Benzo (a) anthracene	10				
Benzo (b) flouranthene	10				
Benzo (k) flouranthene	10				
Chrysene	10				
Dibenz (a, h) anthracene	10				
EDB	.05				
1,2-DCA	5				
Lead	Site specific				

## **XV. ANALYTICAL RESULTS**

**You must submit the laboratory report and chain-of-custody form for the samples. These samples must be analyzed by a South Carolina certified laboratory.**

(Attach Certified Analytical Results and Chain-of-Custody Here)  
(Please see Form #4)



# TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

## ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Nashville

2960 Foster Creighton Drive

Nashville, TN 37204

Tel: (615)726-0177

TestAmerica Job ID: 490-62548-1

Client Project/Site: Laurel Bay Housing Project


For:

Small Business Group Inc.

10179 Highway 78

Ladson, South Carolina 29456

Attn: Tom McElwee



Authorized for release by:

10/13/2014 11:32:07 AM

Ken Hayes, Project Manager II

(615)301-5035

[ken.hayes@testamericainc.com](mailto:ken.hayes@testamericainc.com)

### LINKS

Review your project  
results through

TotalAccess

Have a Question?

? Ask  
The  
Expert

Visit us at:

[www.testamericainc.com](http://www.testamericainc.com)

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Sample Summary . . . . .	3
Case Narrative . . . . .	4
Definitions . . . . .	5
Client Sample Results . . . . .	6
QC Sample Results . . . . .	8
QC Association . . . . .	13
Chronicle . . . . .	14
Method Summary . . . . .	15
Certification Summary . . . . .	16
Chain of Custody . . . . .	17
Receipt Checklists . . . . .	19





## Sample Summary

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
490-62548-1	252 Beech	Soil	09/24/14 14:15	09/30/14 08:40
490-62548-2	401 Elderberry	Soil	09/25/14 12:45	09/30/14 08:40

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

## Case Narrative

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

**Job ID: 490-62548-1**

**Laboratory: TestAmerica Nashville**

### Narrative

**Job Narrative**  
**490-62548-1**

### Comments

No additional comments.

### Receipt

The samples were received on 9/30/2014 8:40 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 1.6° C.

### GC/MS VOA

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

### GC/MS Semi VOA

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

### Organic Prep

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

### VOA Prep

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

## Definitions/Glossary

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

### Qualifiers

#### GC/MS VOA

Qualifier	Qualifier Description
F1	MS and/or MSD Recovery exceeds the control limits
F2	MS/MSD RPD exceeds control limits

### Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
$\alpha$	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

# Client Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

Client Sample ID: 252 Beech

Date Collected: 09/24/14 14:15

Date Received: 09/30/14 08:40

Lab Sample ID: 490-62548-1

Matrix: Soil

Percent Solids: 82.8

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	ND		0.00197	0.000661	mg/Kg	☐	10/01/14 08:15	10/08/14 02:59	1
Ethylbenzene	ND		0.00197	0.000661	mg/Kg	☐	10/01/14 08:15	10/08/14 02:59	1
Naphthalene	ND		0.00493	0.00168	mg/Kg	☐	10/01/14 08:15	10/08/14 02:59	1
Toluene	ND		0.00197	0.000730	mg/Kg	☐	10/01/14 08:15	10/08/14 02:59	1
Xylenes, Total	ND		0.00296	0.000661	mg/Kg	☐	10/01/14 08:15	10/08/14 02:59	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	112		70 - 130	10/01/14 08:15	10/08/14 02:59	1
4-Bromofluorobenzene (Surr)	110		70 - 130	10/01/14 08:15	10/08/14 02:59	1
Dibromofluoromethane (Surr)	108		70 - 130	10/01/14 08:15	10/08/14 02:59	1
Toluene-d8 (Surr)	100		70 - 130	10/01/14 08:15	10/08/14 02:59	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acenaphthene	ND		0.0612	0.00913	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Acenaphthylene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Anthracene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Benzo[a]anthracene	ND		0.0612	0.0137	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Benzo[a]pyrene	ND		0.0612	0.0110	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Benzo[b]fluoranthene	ND		0.0612	0.0110	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Benzo[g,h,i]perylene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Benzo[k]fluoranthene	ND		0.0612	0.0128	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
1-Methylnaphthalene	ND		0.0612	0.0128	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Pyrene	ND		0.0612	0.0110	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Phenanthrene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Chrysene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Dibenz(a,h)anthracene	ND		0.0612	0.00639	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Fluoranthene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Fluorene	ND		0.0612	0.0110	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Indeno[1,2,3-cd]pyrene	ND		0.0612	0.00913	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
Naphthalene	ND		0.0612	0.00822	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1
2-Methylnaphthalene	ND		0.0612	0.0146	mg/Kg	☐	10/01/14 17:42	10/02/14 21:36	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorobiphenyl (Surr)	46		29 - 120	10/01/14 17:42	10/02/14 21:36	1
Terphenyl-d14 (Surr)	60		13 - 120	10/01/14 17:42	10/02/14 21:36	1
Nitrobenzene-d5 (Surr)	42		27 - 120	10/01/14 17:42	10/02/14 21:36	1

## General Chemistry

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Percent Solids	83		0.10	0.10	%			10/01/14 10:08	1

TestAmerica Nashville



# Client Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

Client Sample ID: 401 Elderberry

Date Collected: 09/25/14 12:45

Date Received: 09/30/14 08:40

Lab Sample ID: 490-62548-2

Matrix: Soil

Percent Solids: 94.1

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	ND		0.00219	0.000732	mg/Kg	☐	10/01/14 08:15	10/08/14 03:28	1
Ethylbenzene	ND		0.00219	0.000732	mg/Kg	☐	10/01/14 08:15	10/08/14 03:28	1
Naphthalene	ND		0.00547	0.00186	mg/Kg	☐	10/01/14 08:15	10/08/14 03:28	1
Toluene	ND		0.00219	0.000809	mg/Kg	☐	10/01/14 08:15	10/08/14 03:28	1
Xylenes, Total	ND		0.00328	0.000732	mg/Kg	☐	10/01/14 08:15	10/08/14 03:28	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	119		70 - 130	10/01/14 08:15	10/08/14 03:28	1
4-Bromofluorobenzene (Surr)	112		70 - 130	10/01/14 08:15	10/08/14 03:28	1
Dibromofluoromethane (Surr)	112		70 - 130	10/01/14 08:15	10/08/14 03:28	1
Toluene-d8 (Surr)	100		70 - 130	10/01/14 08:15	10/08/14 03:28	1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acenaphthene	ND		0.0641	0.00957	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Acenaphthylene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Anthracene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Benzo[a]anthracene	ND		0.0641	0.0144	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Benzo[a]pyrene	ND		0.0641	0.0115	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Benzo[b]fluoranthene	ND		0.0641	0.0115	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Benzo[g,h,i]perylene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Benzo[k]fluoranthene	ND		0.0641	0.0134	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
1-Methylnaphthalene	ND		0.0641	0.0134	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Pyrene	ND		0.0641	0.0115	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Phenanthrene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Chrysene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Dibenz(a,h)anthracene	ND		0.0641	0.00670	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Fluoranthene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Fluorene	ND		0.0641	0.0115	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Indeno[1,2,3-cd]pyrene	ND		0.0641	0.00957	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
Naphthalene	ND		0.0641	0.00861	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1
2-Methylnaphthalene	ND		0.0641	0.0153	mg/Kg	☐	10/01/14 17:42	10/02/14 21:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorobiphenyl (Surr)	32		29 - 120	10/01/14 17:42	10/02/14 21:58	1
Terphenyl-d14 (Surr)	35		13 - 120	10/01/14 17:42	10/02/14 21:58	1
Nitrobenzene-d5 (Surr)	32		27 - 120	10/01/14 17:42	10/02/14 21:58	1

## General Chemistry

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Percent Solids	94		0.10	0.10	%			10/01/14 10:08	1

TestAmerica Nashville

# QC Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

## Method: 8260B - Volatile Organic Compounds (GC/MS)

Lab Sample ID: 490-62524-B-1-D MS

Matrix: Solid

Analysis Batch: 196073

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 194220

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	0.00374		0.0539	0.04091		mg/Kg	☒	69	31 - 143
Ethylbenzene	0.00125	J	0.0539	0.05851		mg/Kg	☒	106	23 - 161
Naphthalene	ND		0.0539	0.1078	F1	mg/Kg	☒	200	10 - 176
Toluene	0.00178	J	0.0539	0.04985		mg/Kg	☒	89	30 - 155
Xylenes, Total	0.00938		0.162	0.1679		mg/Kg	☒	98	25 - 162
MS MS									
Surrogate	%Recovery	Qualifier	Limits						
1,2-Dichloroethane-d4 (Surr)	94		70 - 130						
4-Bromofluorobenzene (Surr)	117		70 - 130						
Dibromofluoromethane (Surr)	93		70 - 130						
Toluene-d8 (Surr)	104		70 - 130						

Lab Sample ID: 490-62524-B-1-E MSD

Matrix: Solid

Analysis Batch: 196073

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 194220

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Benzene	0.00374		0.0580	0.04582		mg/Kg	☒	73	31 - 143	11	50
Ethylbenzene	0.00125	J	0.0580	0.05310		mg/Kg	☒	89	23 - 161	10	50
Naphthalene	ND		0.0580	0.04971	F2	mg/Kg	☒	86	10 - 176	74	50
Toluene	0.00178	J	0.0580	0.04970		mg/Kg	☒	83	30 - 155	0	50
Xylenes, Total	0.00938		0.174	0.1374		mg/Kg	☒	74	25 - 162	20	50
MSD MSD											
Surrogate	%Recovery	Qualifier	Limits								
1,2-Dichloroethane-d4 (Surr)	90		70 - 130								
4-Bromofluorobenzene (Surr)	115		70 - 130								
Dibromofluoromethane (Surr)	91		70 - 130								
Toluene-d8 (Surr)	103		70 - 130								

Lab Sample ID: MB 490-196073/8

Matrix: Solid

Analysis Batch: 196073

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	ND		0.00200	0.000670	mg/Kg			10/08/14 02:30	1
Ethylbenzene	ND		0.00200	0.000670	mg/Kg			10/08/14 02:30	1
Naphthalene	ND		0.00500	0.00170	mg/Kg			10/08/14 02:30	1
Toluene	ND		0.00200	0.000740	mg/Kg			10/08/14 02:30	1
Xylenes, Total	ND		0.00300	0.000670	mg/Kg			10/08/14 02:30	1
MB MB									
Surrogate	%Recovery	Qualifier	Limits						
1,2-Dichloroethane-d4 (Surr)	115		70 - 130						
4-Bromofluorobenzene (Surr)	111		70 - 130						
Dibromofluoromethane (Surr)	109		70 - 130						
Toluene-d8 (Surr)	99		70 - 130						

TestAmerica Nashville



## QC Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

### Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 490-196073/4

Matrix: Solid

Analysis Batch: 196073

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits	
Benzene	0.0500	0.04491		mg/Kg		90	75 - 127	
Ethylbenzene	0.0500	0.05117		mg/Kg		102	80 - 134	
Naphthalene	0.0500	0.04622		mg/Kg		92	69 - 150	
Toluene	0.0500	0.04683		mg/Kg		94	80 - 132	
Xylenes, Total	0.150	0.1364		mg/Kg		91	80 - 137	

Surrogate	LCS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	93		70 - 130
4-Bromofluorobenzene (Surr)	104		70 - 130
Dibromofluoromethane (Surr)	93		70 - 130
Toluene-d8 (Surr)	104		70 - 130

Lab Sample ID: LCSD 490-196073/5

Matrix: Solid

Analysis Batch: 196073

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits		RPD	
									RPD	Limit
Benzene	0.0500	0.04582		mg/Kg		92	75 - 127		2	50
Ethylbenzene	0.0500	0.05131		mg/Kg		103	80 - 134		0	50
Naphthalene	0.0500	0.04507		mg/Kg		90	69 - 150		3	50
Toluene	0.0500	0.04779		mg/Kg		96	80 - 132		2	50
Xylenes, Total	0.150	0.1370		mg/Kg		91	80 - 137		0	50

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	94		70 - 130
4-Bromofluorobenzene (Surr)	104		70 - 130
Dibromofluoromethane (Surr)	95		70 - 130
Toluene-d8 (Surr)	104		70 - 130

### Method: 8270D - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 490-194615/1-A

Matrix: Solid

Analysis Batch: 194722

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 194615

Analyte	MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Acenaphthene	ND		0.0670	0.0100	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Acenaphthylene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Anthracene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Benzo[a]anthracene	ND		0.0670	0.0150	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Benzo[a]pyrene	ND		0.0670	0.0120	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Benzo[b]fluoranthene	ND		0.0670	0.0120	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Benzo[g,h,i]perylene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Benzo[k]fluoranthene	ND		0.0670	0.0140	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
1-Methylnaphthalene	ND		0.0670	0.0140	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Pyrene	ND		0.0670	0.0120	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Phenanthrene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1

TestAmerica Nashville

# QC Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 490-194615/1-A

Matrix: Solid

Analysis Batch: 194722

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 194615

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Chrysene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Dibenz(a,h)anthracene	ND		0.0670	0.00700	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Fluoranthene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Fluorene	ND		0.0670	0.0120	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Indeno[1,2,3-cd]pyrene	ND		0.0670	0.0100	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
Naphthalene	ND		0.0670	0.00900	mg/Kg		10/01/14 17:42	10/02/14 17:05	1
2-Methylnaphthalene	ND		0.0670	0.0160	mg/Kg		10/01/14 17:42	10/02/14 17:05	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
2-Fluorobiphenyl (Surr)	70		29 - 120	10/01/14 17:42	10/02/14 17:05	1
Terphenyl-d14 (Surr)	74		13 - 120	10/01/14 17:42	10/02/14 17:05	1
Nitrobenzene-d5 (Surr)	70		27 - 120	10/01/14 17:42	10/02/14 17:05	1

Lab Sample ID: LCS 490-194615/2-A

Matrix: Solid

Analysis Batch: 194722

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 194615

Analyte	Spike Added	LCS LCS		Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Acenaphthylene	1.67	1.196		mg/Kg		72	38 - 120
Anthracene	1.67	1.245		mg/Kg		75	46 - 124
Benzo[a]anthracene	1.67	1.220		mg/Kg		73	45 - 120
Benzo[a]pyrene	1.67	1.244		mg/Kg		75	45 - 120
Benzo[b]fluoranthene	1.67	1.273		mg/Kg		76	42 - 120
Benzo[g,h,i]perylene	1.67	1.270		mg/Kg		76	38 - 120
Benzo[k]fluoranthene	1.67	1.163		mg/Kg		70	42 - 120
1-Methylnaphthalene	1.67	1.151		mg/Kg		69	32 - 120
Pyrene	1.67	1.211		mg/Kg		73	43 - 120
Phenanthrene	1.67	1.195		mg/Kg		72	45 - 120
Chrysene	1.67	1.283		mg/Kg		77	43 - 120
Dibenz(a,h)anthracene	1.67	1.256		mg/Kg		75	32 - 128
Fluoranthene	1.67	1.223		mg/Kg		73	46 - 120
Fluorene	1.67	1.242		mg/Kg		75	42 - 120
Indeno[1,2,3-cd]pyrene	1.67	1.233		mg/Kg		74	41 - 121
Naphthalene	1.67	1.202		mg/Kg		72	32 - 120
2-Methylnaphthalene	1.67	1.142		mg/Kg		69	28 - 120

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
2-Fluorobiphenyl (Surr)	66		29 - 120
Terphenyl-d14 (Surr)	73		13 - 120
Nitrobenzene-d5 (Surr)	68		27 - 120

Lab Sample ID: 240-42495-C-1-B MS

Matrix: Solid

Analysis Batch: 194722

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 194615

Analyte	Sample Sample		Spike Added	MS MS		Unit	D	%Rec	%Rec. Limits
	Result	Qualifier		Result	Qualifier				
Acenaphthylene	ND		2.21	1.460		mg/Kg	☐	66	25 - 120
Anthracene	ND		2.21	1.531		mg/Kg	☐	69	28 - 125

TestAmerica Nashville



# QC Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

## Method: 8270D - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 240-42495-C-1-B MS

Matrix: Solid

Analysis Batch: 194722

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 194615

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzo[a]anthracene	ND		2.21	1.557		mg/Kg	☒	70	23 - 120
Benzo[a]pyrene	ND		2.21	1.533		mg/Kg	☒	69	15 - 128
Benzo[b]fluoranthene	ND		2.21	1.543		mg/Kg	☒	70	12 - 133
Benzo[g,h,i]perylene	ND		2.21	1.506		mg/Kg	☒	68	22 - 120
Benzo[k]fluoranthene	ND		2.21	1.572		mg/Kg	☒	71	28 - 120
1-Methylnaphthalene	ND		2.21	1.406		mg/Kg	☒	63	10 - 120
Pyrene	ND		2.21	1.526		mg/Kg	☒	69	20 - 123
Phenanthrene	ND		2.21	1.501		mg/Kg	☒	68	21 - 122
Chrysene	ND		2.21	1.488		mg/Kg	☒	67	20 - 120
Dibenz(a,h)anthracene	ND		2.21	1.542		mg/Kg	☒	70	12 - 128
Fluoranthene	ND		2.21	1.549		mg/Kg	☒	70	10 - 143
Fluorene	ND		2.21	1.499		mg/Kg	☒	68	20 - 120
Indeno[1,2,3-cd]pyrene	ND		2.21	1.502		mg/Kg	☒	68	22 - 121
Naphthalene	ND		2.21	1.436		mg/Kg	☒	65	10 - 120
2-Methylnaphthalene	ND		2.21	1.397		mg/Kg	☒	63	13 - 120
<b>MS MS</b>									
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>						
2-Fluorobiphenyl (Surr)	61		29 - 120						
Terphenyl-d14 (Surr)	69		13 - 120						
Nitrobenzene-d5 (Surr)	63		27 - 120						

Lab Sample ID: 240-42495-C-1-C MSD

Matrix: Solid

Analysis Batch: 194722

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 194615

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Acenaphthylene	ND		2.22	1.371		mg/Kg	☒	62	25 - 120	6	50
Anthracene	ND		2.22	1.442		mg/Kg	☒	65	28 - 125	6	49
Benzo[a]anthracene	ND		2.22	1.450		mg/Kg	☒	65	23 - 120	7	50
Benzo[a]pyrene	ND		2.22	1.422		mg/Kg	☒	64	15 - 128	8	50
Benzo[b]fluoranthene	ND		2.22	1.409		mg/Kg	☒	63	12 - 133	9	50
Benzo[g,h,i]perylene	ND		2.22	1.378		mg/Kg	☒	62	22 - 120	9	50
Benzo[k]fluoranthene	ND		2.22	1.410		mg/Kg	☒	63	28 - 120	11	45
1-Methylnaphthalene	ND		2.22	1.345		mg/Kg	☒	60	10 - 120	4	50
Pyrene	ND		2.22	1.422		mg/Kg	☒	64	20 - 123	7	50
Phenanthrene	ND		2.22	1.416		mg/Kg	☒	64	21 - 122	6	50
Chrysene	ND		2.22	1.375		mg/Kg	☒	62	20 - 120	8	49
Dibenz(a,h)anthracene	ND		2.22	1.414		mg/Kg	☒	64	12 - 128	9	50
Fluoranthene	ND		2.22	1.455		mg/Kg	☒	65	10 - 143	6	50
Fluorene	ND		2.22	1.377		mg/Kg	☒	62	20 - 120	8	50
Indeno[1,2,3-cd]pyrene	ND		2.22	1.388		mg/Kg	☒	62	22 - 121	8	50
Naphthalene	ND		2.22	1.367		mg/Kg	☒	61	10 - 120	5	50
2-Methylnaphthalene	ND		2.22	1.351		mg/Kg	☒	61	13 - 120	3	50
<b>MSD MSD</b>											
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>								
2-Fluorobiphenyl (Surr)	58		29 - 120								
Terphenyl-d14 (Surr)	65		13 - 120								

TestAmerica Nashville

## QC Sample Results

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

### Method: 8270D - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 240-42495-C-1-C MSD  
Matrix: Solid  
Analysis Batch: 194722

Client Sample ID: Matrix Spike Duplicate  
Prep Type: Total/NA  
Prep Batch: 194615

Surrogate	MSD	MSD	Limits
	%Recovery	Qualifier	
Nitrobenzene-d5 (Surr)	59		27 - 120

### Method: Moisture - Percent Moisture

Lab Sample ID: 490-62548-1 DU  
Matrix: Soil  
Analysis Batch: 194433

Client Sample ID: 252 Beech  
Prep Type: Total/NA

Analyte	Sample	Sample	DU	DU	Unit	D	RPD	RPD	Limit
	Result	Qualifier	Result	Qualifier					
Percent Solids	83		83		%		0.6		20

TestAmerica Nashville

## QC Association Summary

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

### GC/MS VOA

#### Prep Batch: 194220

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
490-62524-B-1-D MS	Matrix Spike	Total/NA	Solid	5030C	
490-62524-B-1-E MSD	Matrix Spike Duplicate	Total/NA	Solid	5030C	

#### Prep Batch: 194375

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
490-62548-1	252 Beech	Total/NA	Soil	5035	
490-62548-2	401 Elderbrerry	Total/NA	Soil	5035	

#### Analysis Batch: 196073

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
490-62524-B-1-D MS	Matrix Spike	Total/NA	Solid	8260B	194220
490-62524-B-1-E MSD	Matrix Spike Duplicate	Total/NA	Solid	8260B	194220
490-62548-1	252 Beech	Total/NA	Soil	8260B	194375
490-62548-2	401 Elderbrerry	Total/NA	Soil	8260B	194375
LCS 490-196073/4	Lab Control Sample	Total/NA	Solid	8260B	
LCSD 490-196073/5	Lab Control Sample Dup	Total/NA	Solid	8260B	
MB 490-196073/8	Method Blank	Total/NA	Solid	8260B	

### GC/MS Semi VOA

#### Prep Batch: 194615

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
240-42495-C-1-B MS	Matrix Spike	Total/NA	Solid	3550C	
240-42495-C-1-C MSD	Matrix Spike Duplicate	Total/NA	Solid	3550C	
490-62548-1	252 Beech	Total/NA	Soil	3550C	
490-62548-2	401 Elderbrerry	Total/NA	Soil	3550C	
LCS 490-194615/2-A	Lab Control Sample	Total/NA	Solid	3550C	
MB 490-194615/1-A	Method Blank	Total/NA	Solid	3550C	

#### Analysis Batch: 194722

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
240-42495-C-1-B MS	Matrix Spike	Total/NA	Solid	8270D	194615
240-42495-C-1-C MSD	Matrix Spike Duplicate	Total/NA	Solid	8270D	194615
490-62548-1	252 Beech	Total/NA	Soil	8270D	194615
490-62548-2	401 Elderbrerry	Total/NA	Soil	8270D	194615
LCS 490-194615/2-A	Lab Control Sample	Total/NA	Solid	8270D	194615
MB 490-194615/1-A	Method Blank	Total/NA	Solid	8270D	194615

### General Chemistry

#### Analysis Batch: 194433

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
490-62548-1	252 Beech	Total/NA	Soil	Moisture	
490-62548-1 DU	252 Beech	Total/NA	Soil	Moisture	
490-62548-2	401 Elderbrerry	Total/NA	Soil	Moisture	

TestAmerica Nashville



## Lab Chronicle

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

### Client Sample ID: 252 Beech

Date Collected: 09/24/14 14:15

Date Received: 09/30/14 08:40

### Lab Sample ID: 490-62548-1

Matrix: Soil

Percent Solids: 82.8

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	5035			6.12 g	5.0 mL	194375	10/01/14 08:15	JLP	TAL NSH
Total/NA	Analysis	8260B		1	6.12 g	5.0 mL	196073	10/08/14 02:59	KKK	TAL NSH
Total/NA	Prep	3550C			39.70 g	1.00 mL	194615	10/01/14 17:42	RMS	TAL NSH
Total/NA	Analysis	8270D		1	39.70 g	1.00 mL	194722	10/02/14 21:36	KKH	TAL NSH
Total/NA	Analysis	Moisture		1			194433	10/01/14 10:08	RRS	TAL NSH

### Client Sample ID: 401 Elderberry

Date Collected: 09/25/14 12:45

Date Received: 09/30/14 08:40

### Lab Sample ID: 490-62548-2

Matrix: Soil

Percent Solids: 94.1

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	5035			4.861 g	5.0 mL	194375	10/01/14 08:15	JLP	TAL NSH
Total/NA	Analysis	8260B		1	4.861 g	5.0 mL	196073	10/08/14 03:28	KKK	TAL NSH
Total/NA	Prep	3550C			33.32 g	1.00 mL	194615	10/01/14 17:42	RMS	TAL NSH
Total/NA	Analysis	8270D		1	33.32 g	1.00 mL	194722	10/02/14 21:58	KKH	TAL NSH
Total/NA	Analysis	Moisture		1			194433	10/01/14 10:08	RRS	TAL NSH

#### Laboratory References:

TAL NSH = TestAmerica Nashville, 2960 Foster Creighton Drive, Nashville, TN 37204, TEL (615)726-0177

## Method Summary

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

Method	Method Description	Protocol	Laboratory
8260B	Volatile Organic Compounds (GC/MS)	SW846	TAL NSH
8270D	Semivolatile Organic Compounds (GC/MS)	SW846	TAL NSH
Moisture	Percent Moisture	EPA	TAL NSH

### Protocol References:

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

### Laboratory References:

TAL NSH = TestAmerica Nashville, 2960 Foster Creighton Drive, Nashville, TN 37204, TEL (615)726-0177

## Certification Summary

Client: Small Business Group Inc.  
Project/Site: Laurel Bay Housing Project

TestAmerica Job ID: 490-62548-1

### Laboratory: TestAmerica Nashville

Unless otherwise noted, all analytes for this laboratory were covered under each certification below.

Authority	Program	EPA Region	Certification ID	Expiration Date
North Carolina (WW/SW)	State Program	4	387	12-31-14
The following analytes are included in this report, but certification is not offered by the governing authority:				
Analysis Method	Prep Method	Matrix	Analyte	
Moisture		Soil	Percent Solids	
South Carolina	State Program	4	84009 (001)	02-28-15
The following analytes are included in this report, but certification is not offered by the governing authority:				
Analysis Method	Prep Method	Matrix	Analyte	
8270D	3550C	Soil	1-Methylnaphthalene	
Moisture		Soil	Percent Solids	

## COOLER RECEIPT FORM



Cooler Received/Opened On 9/30/2014 @ 0840

1. Tracking # 4004 (last 4 digits, FedEx)

Courier: FedEx IR Gun ID 94660220

2. Temperature of rep. sample or temp blank when opened: 1.6 Degrees Celsius

3. If Item #2 temperature is 0°C or less, was the representative sample or temp blank frozen? YES NO NA

4. Were custody seals on outside of cooler? YES...NO...NA

If yes, how many and where: 12 From 1/Back

5. Were the seals intact, signed, and dated correctly? YES...NO...NA

6. Were custody papers inside cooler? YES...NO...NA

I certify that I opened the cooler and answered questions 1-6 (initial) MDM

7. Were custody seals on containers: YES NO and intact YES...NO...NA

Were these signed and dated correctly? YES...NO...NA

8. Packing mat'l used? Bubblewrap Plastic bag Peanuts Vermiculite Foam Insert Paper Other None

9. Cooling process: Ice Ice-pack Ice (direct contact) Dry ice Other None

10. Did all containers arrive in good condition (unbroken)? YES...NO...NA

11. Were all container labels complete (#, date, signed, pres., etc)? YES...NO...NA

12. Did all container labels and tags agree with custody papers? YES...NO...NA

13a. Were VOA vials received? YES...NO...NA

b. Was there any observable headspace present in any VOA vial? YES...NO...NA

14. Was there a Trip Blank in this cooler? YES NO...NA If multiple coolers, sequence # 1

I certify that I unloaded the cooler and answered questions 7-14 (initial) ADH

15a. On pres'd bottles, did pH test strips suggest preservation reached the correct pH level? YES...NO...NA

b. Did the bottle labels indicate that the correct preservatives were used YES...NO...NA

16. Was residual chlorine present? YES...NO...NA

I certify that I checked for chlorine and pH as per SOP and answered questions 15-16 (initial) ADH

17. Were custody papers properly filled out (ink, signed, etc)? YES...NO...NA

18. Did you sign the custody papers in the appropriate place? YES...NO...NA

19. Were correct containers used for the analysis requested? YES...NO...NA

20. Was sufficient amount of sample sent in each container? YES...NO...NA

I certify that I entered this project into LIMS and answered questions 17-20 (initial) ADH

I certify that I attached a label with the unique LIMS number to each container (initial) ADH

21. Were there Non-Conformance issues at login? YES...NO Was a NCM generated? YES...NO...# 5



# TestAmerica

**THE LEADER IN ENVIRONMENTAL TESTING**  
2500 Foster Creighton  
Nashville TN 37204

Nashville Division  
2960 Foster Creighton  
Nashville, TN 37204

Phone: 615-726-0177  
Toll Free: 800-765-0980  
Fax: 615-726-3404

Loc: 490  
62548

To assist us in using the proper analytical methods, is this work being conducted for regulatory purposes?

Client Name/Account #: EEG - SBG # 2449

Address: 10179 Highway 78

City/State/Zip: Ladson, SC 29456

Project Manager: Tom McElwee email: [mcelwee@eedinc.net](mailto:mcelwee@eedinc.net)

Telephone Number: 843.412.2097

Sampler Name: (Print)

Samir Sinha

Compliance Monitoring?  
Enforcement Action?

Site State: SC

PO#

TA Quote #:

Project ID: 1491491 Bay Housing Project

Project #1-

[illegible]



## Login Sample Receipt Checklist

Client: Small Business Group Inc.

Job Number: 490-62548-1

Login Number: 62548

List Number: 1

Creator: Huskey, Adam

List Source: TestAmerica Nashville

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

ATTACHMENT A



# NON-HAZARDOUS MANIFEST

NON-HAZARDOUS MANIFEST		1. Generator's US EPA ID No.		Manifest Doc No.		2. Page 1 of 1		
3. Generator's Mailing Address: MCAS BEAUFORT LAUREL BAY HOUSING BEAUFORT, SC 29904		Generator's Site Address (if different than mailing): S/A		A. Manifest Number WMNA 01519116		B. State Generator's ID		
4. Generator's Phone 843-879-0411		5. Transporter 1 Company Name Carolina Containers P.O. Box 1925 Beaufort, SC 29901		6. US EPA ID Number		C. State Transporter's ID		
7. Transporter 2 Company Name		8. US EPA ID Number		D. Transporter's Phone		E. State Transporter's ID		
9. Designated Facility Name and Site Address HICKORY HILL LANDFILL 2621 LOW COUNTRY DRIVE RIDGELAND, SC 29936		10. US EPA ID Number		F. Transporter's Phone		G. State Facility ID		
				H. State Facility Phone 843-987-4643				
GENERATOR	11. Description of Waste Materials			12. Containers		13. Total Quantity	14. Unit Wt./Vol.	I. Misc. Comments
	a. HEATING OIL TANK FILLED WITH SAND WM Profile # 102655SC			No.	Type			
				1	30g	598	TON	749170
	b. WM Profile #							
	c. WM Profile #							
TRANSPORTER	d. WM Profile #							
	J. Additional Descriptions for Materials Listed Above			K. Disposal Location				
FACILITY				Cell	Level			
				Grid				
	15. Special Handling Instructions and Additional Information UST's from: 1) 252 BEECH ✓ 2) 401 ELDERBERRY ✓ 3) 435 ELDERBERRY ✓ 4) 437 ELDERBERRY - 2 ✓ 5) 462 CARDINAL							
	Purchase Order #			EMERGENCY CONTACT / PHONE NO.:				
	16. GENERATOR'S CERTIFICATE: I hereby certify that the above-described materials are not hazardous wastes as defined by 40 CFR Part 261 or any applicable state law, have been fully and accurately described, classified and packaged and are in proper condition for transportation according to applicable regulations.							
TRANSPORTER	Printed Name W.G. D... ..		Signature "On behalf of"			Month	Day	Year
						12	01	14
	17. Transporter 1 Acknowledgement of Receipt of Materials							
TRANSPORTER	Printed Name PRATT SHAW		Signature			Month	Day	Year
						12	1	14
	18. Transporter 2 Acknowledgement of Receipt of Materials							
FACILITY	Printed Name MICHAEL BROICH		Signature			Month	Day	Year
						12	2	14
	19. Certificate of Final Treatment/Disposal I certify, on behalf of the above listed treatment facility, that to the best of my knowledge, the above-described waste was managed in compliance with all applicable laws, regulations, permits and licenses on the dates listed above.							
FACILITY	20. Facility Owner or Operator: Certification of receipt of non-hazardous materials covered by this manifest.							
	Printed Name JOAN COFIELD		Signature			Month	Day	Year
					12	2	14	

White- TREATMENT, STORAGE, DISPOSAL FACILITY COPY

Blue- GENERATOR #2 COPY

Yellow- GENERATOR #1 COPY

Pink- FACILITY USE ONLY

Gold- TRANSPORTER #1 COPY

## **Appendix C**

### **Regulatory Correspondence**





Catherine E. Heigel, Director

*Promoting and protecting the health of the public and the environment*

July 1, 2015

Commanding Officer  
Attention: NREAO Mr. William A. Drawdy  
United State Marine Corps Air Station  
Post Office Box 55001  
Beaufort, SC 29904-5001

RE: No Further Action  
Laurel Bay Underground Storage Tank Assessment Reports for:  
*See attached sheet*

Dear Mr. Drawdy,

The South Carolina Department of Health and Environmental Control (the Department) received the referenced Underground Storage Tanks (USTs) Assessment Reports for the addresses listed above. The regulatory authority for the investigation and cleanup of releases from these tank systems is the South Carolina Pollution Control Act (S.C. Code Ann. §48-1-10 et seq., as amended).

The Department has reviewed the referenced assessment reports and agrees there is no indication of soil or groundwater contamination on these properties, and therefore no further investigation is required at this time.

Please note that the Department's decision is based on information provided by the Marine Corps Air Station (MCAS) to date. Any information found to be contradictory to this decision may require additional action. Furthermore, the Department retains the right to request further investigation if deemed necessary.

If you have any questions, please contact me at [kriegkm@dhec.sc.gov](mailto:kriegkm@dhec.sc.gov) or 803-898-0255.

Sincerely,

Kent Krieg  
Department of Defense Corrective Action Section  
Bureau of Land and Waste Management  
South Carolina Department of Health and Environmental Control

Cc: Russell Berry (via email)  
Craig Ehde (via email)  
Bryan Beck (via email)



Catherine E. Heigel, Director

*Promoting and protecting the health of the public and the environment*

**Attachment to:** Krieg to Drawdy  
**Subject:** NFA  
**Dated** 7/1/2015

**Laurel Bay Underground Storage Tank Assessment Reports for: (153 addresses/161 tanks)**

111 Birch	363 Aspen
123 Banyan	364 Aspen
131 Banyan	366 Aspen
134 Banyan	369 Aspen
145 Laurel Bay	373 Aspen
150 Laurel Bay	381 Aspen
153 Laurel Bay	401 Elderberry
154 Laurel Bay	402 Elderberry
155 Laurel Bay	404 Elderberry
200 Balsam	410 Elderberry
202 Balsam	420 Elderberry
203 Balsam	424 Elderberry
208 Balsam	435 Elderberry Tank 3
210 Balsam	452 Elderberry
211 Balsam	460 Elderberry
220 Cypress	465 Dogwood
222 Cypress	477 Laurel Bay
223 Cypress	487 Laurel Bay
252 Beech Tank 2	513 Laurel Bay
271 Beech Tank 1	519 Laurel Bay
271 Beech Tank 2	524 Laurel Bay
284 Birch Tank 1	535 Laurel Bay
284 Birch Tank 2	553 Dahlia
308 Ash	590 Aster
311 Ash	591 Aster
312 Ash	610 Dahlia
317 Ash	612 Dahlia
318 Ash	628 Dahlia
337 Ash	636 Dahlia
351 Ash Tank 1	637 Dahlia Tank 1
351 Ash Tank 2	637 Dahlia Tank 2
355 Ash Tank 1	641 Dahlia
355 Ash Tank 2	642 Dahlia Tank 1
360 Aspen	642 Dahlia Tank 2

**Laurel Bay Underground Storage Tank Assessment Reports for: (153 addresses/161 tanks) cont.**

655 Camellia	920 Albacore
662 Camellia	922 Barracuda Tank 1
683 Camellia	922 Barracuda Tank 2
684 Camellia	924 Albacore
689 Abelia	925 Albacore
694 Abelia	926 Albacore
695 Abelia	930 Albacore
741 Blue Bell	931 Albacore
742 Blue Bell	933 Albacore
755 Althea	936 Albacore
757 Althea	938 Albacore
776 Laurel Bay	939 Albacore
777 Azalea	940 Albacore
779 Laurel Bay	1010 Foxglove
781 Laurel Bay	1066 Gardenia
802 Azalea	1068 Gardenia
816 Azalea	1071 Heather Tank 2
822 Azalea	1100 Iris Tank 2
823 Azalea	1128 Iris
825 Azalea	1178 Bobwhite
828 Azalea	1204 Cardinal
837 Azalea	1208 Cardinal
851 Dolphin	1209 Cardinal
856 Dolphin	1210 Cardinal
857 Dolphin	1215 Cardinal
861 Dolphin	1216 Cardinal
864 Dolphin	1217 Cardinal Tank 1
868 Dolphin	1217 Cardinal Tank 2
872 Dolphin	1233 Dove
879 Cobia	1244 Dove
886 Cobia	1250 Dove
888 Cobia	1252 Dove
889 Cobia	1254 Dove
901 Barracuda	1256 Dove
902 Barracuda	1258 Dove
903 Barracuda	1263 Dove
904 Barracuda	1269 Dove
909 Barracuda	1276 Dove
910 Barracuda	1283 Dove
914 Barracuda	1285 Dove
915 Barracuda	1288 Eagle

**Laurel Bay Underground Storage Tank Assessment Reports for: (153 addresses/161 tanks) cont.**

1296 Eagle	1330 Albatross
1307 Eagle	1331 Albatross
1321 Albatross	1333 Albatross
1322 Albatross	1334 Albatross
1327 Albatross	1335 Albatross
1328 Albatross	